

To all food vendors:

The following list must be completely complied with before approval can be given to operate at Big Spring Jam 2008.

- 1- All propane tanks must be secured so they can't be knocked over during operation, or storage.
- 2- All tents or mobile kitchens must have a 5-pound fire extinguisher with a tag indicating service within the last 12 months. If the extinguisher was purchased within the last 12 months, you must present a receipt of purchase upon inspection.
- 3- If cooking consists of any type of frying operations a K-Class fire extinguisher with a current certification tag, or a receipt where the extinguisher has been purchased within the last 12 months must be present
- 4- If you furnish your own tent, the tent must display a fire retardant tag complying with NFPA 701 test on the flap. If the tent has sides, the sides must comply with the same standard. If the tent does not meet the NFPA 701 requirements it can't be used. E-Z Up tents do not meet this requirement. Non compliant tents may be used for other non public use but must be **MINIMUM 5 FEET AWAY FROM OTHER TENTS OR ANY COOKING OPERATIONS. NO EXCEPTIONS.**
- 5- There will be no smoking allowed under any tent. All tents must have no smoking signs displayed.
- 6- If tents are used for public use, you must have a clearly marked unobstructed exit or exits.
- 7- Any extension cord must be at least 16-gauge wire.
- 8- Extension cords must be in good repair. The cord must be free of any frays or splices.
- 9- Extension cords in tents must be tie wrapped to the poles of the tent.
- 10- All extension cords must have a ground on the male and female side of the cord.
- 11- All plugs including the power source for the extension cord must be protected from moisture by a plastic bag.

Gregory W Spruell
Fire Prevention Officer.